



PUNE MUNICIPAL CORPORATION

Date : 02/07/2021

Parvati Water Works Laboratory

Report ID : CH30

Report of Water Samples Collected as on 29/06/2021

पुणे महानगरपालिका

पर्वती जलकेंद्र पुणे ३०.

Challan No : 12423000002

Challan Date : 29/06/2021

Amount (Rs.): 1620.0

जायक क्र. - CH-30

मालकाचे नाव : ARYANS WORLD SCHOOL

दिनांक - ०२/०७/२०२१

1) Aryans world school,warje pune Drinking water sample.

As per I.S Standard No. 10500:2012				
Parameter	Results	Desirable Limit	Permissible Limit	Unit
PH	7.21	Between 6.5 To 8.5	No Relaxation	-
Turbidity	0.6	Max 1	Max 5	N.T.U
Total Hardness (as CaCO ₃)	24.0	Max 200	Max 600	PPM
Chlorides (as Cl)	18.0	Max 250	Max 1000	PPM
Alkanity (as calcium carbonate)	28.0	Max 200	Max 600	PPM
Nitrate Nitrogen (as NO ₃)	0.4	Max 45	No relaxation	PPM
Nitrite Nitrogen (as NO ₂)	0.01	-	-	PPM
Coliform	0	0	0	100ml
E-Coli	0	0	0	100ml
Residual Chlorine Test	0.7	0.2	-	PPM

Remark : सदरचा नमुना / नमुने मालकांनी स्वतः आणून दिला. उपरोक्त नमुना / नमुने हा प्रातिनिधिक असल्याचे गृहीत धरले आहे. सदरचा अहवाल हा वैयक्तिक माहितीसाठी असून, याचा वापर कुठल्याही प्रकारचा परवान्यासाठी केल्याने उद्भवणाऱ्या कायदेशीर बाबींस हे कार्यालय जबाबदार असणार नाही. तसेच नमुनांच्या उद्गमाविषयीचा पडताळा ह्या कार्यालयामार्फत केलेला नाही.

शेरा :

Above water sample is potable for drinking purpose.

28/6/20
केमिस्ट
पर्वती जलकेंद्र
पुणे महानगरपालिका

SAFE SANITARY CONDITION CERTIFICATE

No. आरोग्य /PMC/NO/73

Date: 05/07/2021

It is certified that an inspection team headed by Shree. Vishal Jagdale (Building Inspector) (Name of Officers with designation) from Health as Sanitary department (PMC) Pune (Name of Department/Office) Inspected the Aaryans World School, Warje Pune (Name of School) is maintaining the hygienic sanitation condition facilities for the students and members of staff of the institution in the school building & the campus as per the norms prescribed by the Central/State/U.T Gove.
The above valid for a period of Three years
The above certificate is issued to Aaryans World School, Warje on their request for the purpose of affiliation.



Signature with Seal: V. Jagdale

Name: Mr. Vishal Jagdale

Designation: Building Inspector

To The Principal
Aaryans World School
Warje Pune, 411058

M. Kulkarni
PRINCIPAL
Aaryans World School
S.No. 15/1,2,3. Near Jijai Garden,
Tapodham Road,
Warje, Pune - 411058.